

ADDENDUM E4

ST. MICHAELS HOSPITAL
TYNDALL, SOUTH DAKOTA

DATE: May 6, 2014

Associated Consulting Engineering, Inc.
340 S. Phillips Ave.
Sioux Falls SD 57104-6910

SCOPE OF THIS ADDENDUM:

The following becomes a part of the original Drawings and Project Manual, taking precedence over those items that may conflict.

The Bidder shall note receipt and make acknowledgment of this addendum on the bid form, incorporating its provisions in their bid.

This addendum has been issued to all bidders and to all others to whom Drawings and Project Manuals have been issued by the office of the Architect/Engineer.

DRAWING ITEMS:

DRAWING SHEET E2.2

FLOOR PLAN – POWER & SIGNAL

1. In reference to nurse call system, provide a single-gang rough-in for the patient room bathroom applications and remove one of the 3-gang junction box rough-ins on the patient head wall. Coordinate exact requirements with nurse call system supplier.

SUBSTITUTIONS AND PRODUCT OPTIONS

The following material or equipment furnished by the manufacturers listed may be substituted as equal, providing that each item, material and piece of equipment conforms to the design and requirements of the Drawings and Project Manual.

| SECTION | ITEM | MANUFACTURER |
|---------------|----------------------------|--------------|
| 265110/265210 | Interior/Exterior Lighting | |
| | Type A Series | Metalux |
| | Type A3 | Fail-Safe |
| | Type D | Metalux |
| | Type E | Sure-Lites |
| | Type F Series | Metalux |
| | Type G | Metalux |
| | Type H | Atlantic |
| | Type K | Teron |
| | Type L | Fail-Safe |
| | Type P | Shaper |
| | Type Y | Lumark |

END OF ADDENDUM